

Building ID	Sample Date	Fixture Type	Sample Type	Concentration (ug/L)	Notes
Taylor Park	10/19/17	S - Sink	First Draw	7.90	need to flush for 60 seconds before use
Taylor Park	10/19/17	S - Sink	Flush	< 2.00	need to flush for 60 seconds before use
Taylor Park	10/19/17	DF - Drinking Fountain	First Draw	< 2.00	
Taylor Park	10/19/17	DF - Drinking Fountain	Flush	< 2.00	
Taylor Park	10/19/17	DF - Drinking Fountain	First Draw	< 2.00	
Taylor Park	10/19/17	DF - Drinking Fountain	Flush	< 2.00	
Taylor Park	10/19/17	DF - Drinking Fountain	First Draw	< 2.00	
Taylor Park	10/19/17	DF - Drinking Fountain	Flush	< 2.00	
Taylor Park	10/19/17	DF - Drinking Fountain	First Draw	< 2.00	
Taylor Park	10/19/17	DF - Drinking Fountain	Flush	< 2.00	
Taylor Park	10/19/17	DF - Drinking Fountain	First Draw	< 2.00	
Taylor Park	10/19/17	DF - Drinking Fountain	Flush	< 2.00	
Taylor Park	10/19/17	DF - Drinking Fountain	First Draw	< 2.00	
Taylor Park	10/19/17	DF - Drinking Fountain	Flush	< 2.00	
Taylor Park	10/19/17	DF - Drinking Fountain	First Draw	< 2.00	
Taylor Park	10/19/17	DF - Drinking Fountain	Flush	< 2.00	
Taylor Park	10/19/17	DF - Drinking Fountain	First Draw	< 2.00	
Taylor Park	10/19/17	DF - Drinking Fountain	Flush	< 2.00	